

Emission Test Certificate

Tuesday 2nd April 2019

Supplier: Godfrey Hirst Australia (7 Factories Road, Geelong, VIC 3220)

Sample Description: GH LVP DS & DS Plus 1498 x 246 x 4.5 mm

Date Tested: March 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hours):

Global GreenTag	GH LVP DS & DS Plus 1498 x 246 x 4.5 mm
Total Volatile Organic Compound Emission Rate Limit: <0.500 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: 0.043 mg/m ² /hr
4-phenylcyclohexene Emission Rate Limit: <0.05 mg/m ² /hr	4-phenylcyclohexene Emission Rate: <0.005 mg/m ² /hr
Formaldehyde Emission Rate Limit: <0.1 mg/m ² /hr	Formaldehyde Emission Rate: 0.026 mg/m ² /hr



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B.Eng. (Chemical)
Consultant

CV190355