

Emission Test Certificate

Wednesday March 29th, 2006

Supplier: Godfrey Hirst Australia Pty Ltd (2 Gilbertson Road, Laverton North Victoria 3026)

Sample Description: Kingsgate Town Wool Blend Broadloom Carpet

Date Tested: March 2006

Test Method: Carpet & Rug Institute Green Label Plus test program incorporating
ASTM D5116-97 “Standard Guide for Small-Scale Environmental Chamber
Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Carpet & Rug Institute Green Label Plus Specification	Kingsgate Town Wool Blend Broadloom
Total Volatile Organic Compound emission rate < 0.5 mg/m ² /hr (14 days)	Total Volatile Organic Compound emission rate 0.036 mg/m ² /hr (14 days)
<p>“Chemicals of Concern”:</p> <ul style="list-style-type: none"> Formaldehyde Acetaldehyde Benzene Caprolactam 2-Ethylhexanoic Acid 1-Methyl-2-Pyrrolidinone Naphthalene Nonanal Octanal 4-Phenylcyclohexene Styrene Toluene Vinyl Acetate 	<p>Emission Rate:</p> <ul style="list-style-type: none"> < 0.001 mg/m²/hr < 0.001 mg/m²/hr < 0.001 mg/m²/hr < 0.001 mg/m²/hr < 0.005 mg/m²/hr < 0.002 mg/m²/hr < 0.001 mg/m²/hr < 0.001 mg/m²/hr < 0.001 mg/m²/hr < 0.001 mg/m²/hr < 0.011 mg/m²/hr < 0.001 mg/m²/hr <p>The “chemicals of concern” were present in the product to a very low extent and would pose insignificant health effect to building occupants when used in the typical manner.</p>

Emission Test Certificate

The above results may be considered representative of the entire range of Wool Blend Broadloom carpets supplied by Godfrey Hirst Australia Pty Ltd as advised by Godfrey Hirst Australia Pty Ltd.

These include the following:

- Kingsgate Town
- Boucle Twist
- Maddison
- Cube
- Tempo
- Casa Velour
- Condo Plush
- Millbrook
- Casa Twist
- Tibet
- Tendril
- Divine
- Sierra
- Kingsgate Town 48oz
- Angelique



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant